

# AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTa Product Testing  
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031  
P.O Box 240, North Melbourne, Victoria 3051  
Phone (03) 9371 2400

## Group Number Assessment

(In accordance with AS 5637.1-2015

This is to confirm that the product as described below has been tested by AWTa Product Testing.

Testing was performed in accordance with AS/NZS 3837-1998 Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter.

As per AS 5637.1 Clause 9(n) it was valid to test this particular material / system in the cone calorimeter for the assignment of a NCC Group Number.

<b>Test Sponsor :</b>	Warwick Fabrics Aust Pty Ltd 6-10 Sackville Street Collingwood VIC 3066	<b>Test Number :</b>	25-004825
		<b>Issue Date :</b>	17/11/2025
		<b>Print Date :</b>	17/11/2025

<b>Sponsor Product :</b>	Clients Ref : "Brooklyn" Luciana Wallis
	Woven fabric
	Colour : Biscuit
	End Use : Upholstery
	Nominal Composition : 100% Polyester
	Nominal Mass per Unit Area/Density : 355g/m <sup>2</sup>
	Nominal Thickness : 1mm



80584

The message/document(s) contained in this electronic attachment is intended for the party to which it is addressed and may contain confidential information or be subject to professional privilege. Its transmission is not intended to place the contents into the public domain.

If you have received this transmission in error, its disclosure or copying is prohibited. Please contact us by collect call so that arrangements can be made at our expense to rectify the error.

# AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTa Product Testing  
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031  
P.O Box 240, North Melbourne, Victoria 3051  
Phone (03) 9371 2400

## Group Number Assessment

(In accordance with AS 5637.1-2015

This is to confirm that the product as described below has been tested by AWTa Product Testing.

Testing was performed in accordance with AS/NZS 3837-1998 Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter.

As per AS 5637.1 Clause 9(n) it was valid to test this particular material / system in the cone calorimeter for the assignment of a NCC Group Number.

<b>Test Sponsor :</b>	Warwick Fabrics Aust Pty Ltd 6-10 Sackville Street Collingwood VIC 3066	<b>Test Number :</b>	25-004825
		<b>Issue Date :</b>	17/11/2025
		<b>Print Date :</b>	17/11/2025

Product Group Number Classification :	1
Average Specific Extinction Area :	94.9 m <sup>2</sup> /kg



Chris Campbell  
Client Relations Manager

80584

The message/document(s) contained in this electronic attachment is intended for the party to which it is addressed and may contain confidential information or be subject to professional privilege. Its transmission is not intended to place the contents into the public domain.

If you have received this transmission in error, its disclosure or copying is prohibited. Please contact us by collect call so that arrangements can be made at our expense to rectify the error.